

ADDENDUM NO. 1
CLARIFICATION
FOR
Cranberry Wells GAC Replacement

This Addendum No. 1 forms a part of the Contract Documents and modifies the Bidding Documents posted as noted below. Acknowledge receipt of this Addendum in the space provided in the FORM FOR "BID PROPOSAL". Failure to do so may subject the Bidder to disqualifications. This Addendum consists of 2 pages.

1. Under PART 2- EXECUTION, 3.1 – Installation, Sub-section C, Numbers 1, 2, 3, 4, and 5 on page 466313.11-5:

C. Provide labor, equipment, tools, and connections required to complete backwash of GAC media.

1. Backwash vessels after GAC media installation to produce a 30 percent bed expansion with 55-75-degree F water.
2. Do not allow uncontrolled discharge of backwash water.
3. Provide temporary piping for routing of backwash water to temporary containment. Connect to 8-inch diameter flanged discharge point and route piping to containment.
4. Provide temporary piping and storage tanks of adequate volume to contain water produced by backwashing. Minimum volume: 40,000 gallons.
5. Provide dechlorination of backwash water prior to discharge to stormwater. Provide piping, valves, and appurtenances as required to control discharge flow and prevent overland flow, erosion, and damage to adjacent wetlands.

This work will be executed by Town of Hudson Department of Public Works staff. Bidders will NOT be required to submit this information for their bid packages.

****END OF ADDENDUM 1****