

April 12, 2024

**ADDENDUM NO. 1
TO
DOCUMENTS AND SPECIFICATIONS
Water Quality Testing & Reporting**

This Addendum No. 1 forms a part of the Contract Documents and modifies the Bidding Documents dated April 8, 2024 as noted below. Acknowledge receipt of this Addendum in the space provided below. Failure to do so may subject the Bidder to disqualifications. This Addendum consists of 2 pages.

CHANGES MADE TO CONTRACT DOCUMENTS:

1. Question received: "On Page 5 you ask for a Bid Price Per Test and then a Total Analyte Annual Price. However, Quantities Listed are 13-15; 8-10; 125-130 etc. In order to have a fair bid and comparison do we use the lower or higher number?"
a. ANSWER: All bidders should use the lower number.
2. Question received: "On page 5 , PFAS 109-112 Tests, is the Method 537.1 for Drinking Water? Do you want just the PFAS Test or do you require a Blank with each test?"
a. ANSWER: A Field Trip Blank is required for each location sampled. These are included on the 109 to 112 test quantities.
3. Question Received: "I have a question regarding the "Lagoon Wet" line item in the Water Quality Testing bid. Can you tell me what is actually required to be tested for this line item?"
a. ANSWER: Parameters for WETT are included in this addendum, as seen on page two of the addendum.

BIDDER acknowledges receipt of ADDENDA NO. ____ through ____.

Respectfully submitted:

By _____
(Signature of Bidder)

Title _____

Table 3. Summary of Whole Effluent Toxicity Test Monitoring Requirements

Whole Effluent Toxicity				
Parameter	Units	Limitation	Monitoring Frequency	Sample Type
LC ₅₀ (Acute WET Testing)	%	Report %	1/Year	Composite
C-NOEC (Chronic WET Testing)	%	Report %	1/Year	Composite
Hardness	mg/l	Report	1/Year	Composite
Total Residual Chlorine	mg/l	Report	1/Year	Grab
Alkalinity	mg/l	Report	1/Year	Composite
pH	S.U.	Report	1/Year	Grab
Specific Conductance	umhos/cm	Report	1/Year	Composite
Total Solids	mg/l	Report	1/Year	Composite
Total Dissolved Solids	mg/l	Report	1/Year	Composite
Ammonia Nitrogen as N	mg/l	Report	1/Year	Composite
Total Organic Carbon	mg/l	Report	1/Year	Composite
Total Recoverable Aluminum	mg/l	Report	1/Year	Composite
Total Recoverable Cadmium	mg/l	Report	1/Year	Composite
Total Recoverable Copper	mg/l	Report	1/Year	Composite
Total Recoverable Lead	mg/l	Report	1/Year	Composite
Total Recoverable Nickel	mg/l	Report	1/Year	Composite
Total Recoverable Zinc	mg/l	Report	1/Year	Composite
Diluent Whole Effluent Toxicity				
Hardness	mg/l	Report	1/Year	Grab
Alkalinity	mg/l	Report	1/Year	Grab
pH	S.U.	Report	1/Year	Grab
Specific Conductance	umhos/cm	Report	1/Year	Grab